



FIRE EQUIPMENT
I N C O R P O R A T E D

Fire Alarm Inspection Certificate

For

Chapel Hill West Condo
1550 Worcester Rd
Framingham, MA 01702

Tested to NFPA Standards

This Inspection was performed in accordance with NFPA 72 Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.

Inspection Date:
3/20/2023

Inspector Name: Jeremy Bell - T11
Title: Service Technician



FIRE EQUIPMENT INCORPORATED

Report of Inspection, Testing & Maintenance of Fire Alarms

Firm: Fire Equipment Inc.	Inspection Contract#: Chapel Hill West Condo - Child - Quarterly - 526 - Fire Alarm Inspection	
Property Name: Chapel Hill West Condo	Street: 1550 Worcester Rd	City/State/Zip: Framingham, MA 01702
Inspection Frequency: Quarterly	Inspector Name: Jeremy Bell - T11	Date: 03/20/2023
Installed Product: FA 00063398	Product Name: Fire Alarm System	Equipment Location: Building

NOTIFICATIONS MADE PRIOR TO TESTING

Monitoring organization for this equipment::	Masterbox	
Entity to which alarms are retransmitted:	Emergency 24 NE2567 Framingham MB 346 permit required.	
Account or Masterbox #:	346	
System in Service before inspection:	Yes	
Type of System or Service:	Fire Alarm System (non-voice)	
Control Unit Manufacturer:	Harrington	
Control Unit Model Number:	3030	
Primary Power		
Input voltage of control panel:	120	
Control panel amps:	20	
Batteries		
Location:	Panel	
Type:	SLA	
Nominal voltage:	12	
Amp/hour rating:	12	
Battery Date:	03/08/2022	
Location and Description of Annunciator:	Front Lobby, Harrington	
Monitoring organization Contact:	Emergency 24	Date:
Building management Contact:	Yes	Date:
Building occupants Contact:	No	Date:
Authority having jurisdiction Contact:	Framingham FD	Date: 03/20/2023
Other, if required Contact:		Date:

TESTING RESULTS

Control Unit and Related Equipment Description	Comments
Control Unit	Functional Test Pass
Lamps/LEDs/LCDs	Functional Test Pass
Trouble Signals	Functional Test Pass
Disconnect switches	Functional Test Pass
Ground-fault monitoring	Visual Inspection Pass
Supervision	Functional Test Pass



FIRE EQUIPMENT INCORPORATED

Local annunciator	Functional Test	Pass
Remote annunciators	Functional Test	Pass
Other (specify)	Visual Inspection	(4) booster panels

Control Unit Power Supplies
Description

Description		Comments
120-volt power	Visual Inspection	Pass
Battery Condition	Functional Test	Pass
Discharge test	Functional Test	
Charger test	Functional Test	Pass
Other (specify)	Visual Inspection	Hallway Magnetic Door Holders

Monitored Systems
Description

Description		Comments
Engine-driven generator	N/A	
Fire pump	N/A	
Special suppression systems	N/A	
Other (specify)	N/A	

Auxiliary Functions
Description

Description		Comments
Door-releasing devices	Functional Test	Pass
Door unlocking	N/A	
Elevator recall	N/A	
Other (specify)	N/A	

NOTIFICATIONS THAT TESTING IS COMPLETE

Monitoring organization Contact:	Emergency 24	Date:
Building management Contact:	Yes	Date:
Building occupants Contact:	No	Date:
Authority having jurisdiction Contact:	Framingham Fire Dept	Date:
Other, if required Contact:		Date:

SYSTEM RESTORED TO NORMAL OPERATION

Date: 03/20/2023

Inspector Certification:

This system, as specified herein, has been inspected and tested according to all NFPA standards cited herein.

Printed name : Jeremy Bell

Date: 03/20/2023

Organization: Fire Equipment

Title: Technician

COMMENTS: 9/1/22 Quarterly fire alarm inspection. Silent test. Apts on 3,2,1.

5/10/22 Tested unit heat detectors

this quarter. Floors 5,3,2,1.silent test.

3/22 quarterly fire alarm inspection. tested common areas.

Silent test.

12/3/21 tested apts on floors 6,5,4. Silent test.



FIRE EQUIPMENT INCORPORATED

DEVICE SHEET

Devices for Product: FA 00063398					
Device Type	Manufacturer	Model	Address	Location	Test Results
Heat Detector	System Sensor	B501BH	H624	Apt. 511	Pass
Heat Detector	System Sensor	B501BH	H634	Apt. 518	Pass
Heat Detector	System Sensor	5551	H543	Apt.422	Pass
Heat Detector	System Sensor	5551	H403	Apt. 301	Pass
Heat Detector	System Sensor	5551	H404	Apt. 302	Pass
Heat Detector	System Sensor	5551	H407	Apt. 303	Pass
Heat Detector	System Sensor	5551	H408	Apt. 304	Pass
Heat Detector	System Sensor	5551	H410	Apt. 305	Pass
Heat Detector	System Sensor	5551	H411	Apt. 306	Pass
Heat Detector	System Sensor	5551	H414	Apt. 307	Pass
Heat Detector	System Sensor	5551	H415	Apt. 308	Pass
Heat Detector	System Sensor	5551	H421	Apt. 309	Pass
Heat Detector	System Sensor	5551	H422	Apt.310	Pass
Heat Detector	System Sensor	5551	H424	Apt.311	Pass
Heat Detector	System Sensor	5551	H425	Apt.312	Pass
Heat Detector	System Sensor	5551	H427	Apt.313	No Access
Heat Detector	System Sensor	5551	H428	Apt.314	Pass
Heat Detector	System Sensor	5551	H430	Apt.315	Pass
Heat Detector	System Sensor	5551	H431	Apt.316	Pass
Heat Detector	System Sensor	5551	H433	Apt.317	Pass
Heat Detector	System Sensor	5551	H434	Apt.318	Pass
Heat Detector	System Sensor	5551	H436	Apt.319	Pass
Heat Detector	System Sensor	5551	H437	Apt.320	Pass
Heat Detector	System Sensor	5551	H442	Apt.321	Pass
Heat Detector	System Sensor	5551	H443	Apt.322	No Access
Heat Detector	System Sensor	5551	H446	Apt.323	Pass
Heat Detector	System Sensor	5551	H447	Apt.324	Pass
Heat Detector	System Sensor	5551	H449	Apt.325	No Access
Heat Detector	System Sensor	5551	H450	Apt.326	Pass
Heat Detector	System Sensor	5551	H453	Apt.327	Pass
Heat Detector	System Sensor	5551	H454	Apt.328	Pass
Heat Detector	System Sensor	5551	H503	Apt.401	Pass
Heat Detector	System Sensor	5551	H504	Apt.402	Pass
Heat Detector	System Sensor	5551	H507	Apt.403	Pass
Heat Detector	System Sensor	5551	H508	Apt.404	Pass
Heat Detector	System Sensor	5551	H510	Apt.405	Pass
Heat Detector	System Sensor	5551	H511	Apt.406	Pass
Heat Detector	System Sensor	5551	H514	Apt.407	Pass
Heat Detector	System Sensor	5551	H515	Apt.408	Pass
Heat Detector	System Sensor	5551	H521	Apt.409	Pass
Heat Detector	System Sensor	5551	H522	Apt.410	Pass
Heat Detector	System Sensor	5551	H524	Apt.411	Pass
Heat Detector	System Sensor	5551	H525	Apt.412	Pass
Heat Detector	System Sensor	5551	H527	Apt.413	Pass
Heat Detector	System Sensor	5551	H528	Apt.414	Pass
Heat Detector	System Sensor	5551	H530	Apt.415	Pass
Heat Detector	System Sensor	5551	H531	Apt.416	Pass
Heat Detector	System Sensor	5551	H533	Apt.417	Pass
Heat Detector	System Sensor	5551	H534	Apt.418	Pass



FIRE EQUIPMENT INCORPORATED

Heat Detector	System Sensor	5551	H536	Apt.419	Pass
Heat Detector	System Sensor	5551	H537	Apt.420	Pass
Heat Detector	System Sensor	5551	H542	Apt.421	Pass
Heat Detector	System Sensor	5551	H546	Apt.423	Pass
Heat Detector	System Sensor	5551	H547	Apt.424	Pass
Heat Detector	System Sensor	5551	H549	Apt.425	Pass
Heat Detector	System Sensor	5551	H550	Apt.426	Pass
Heat Detector	System Sensor	5551	H553	Apt.427	Pass
Heat Detector	System Sensor	5551	H554	Apt.428	Pass
Photoelectric Smoke	EST	2251 FB	P401	3rd Floor East Stairwell	Pass
Photoelectric Smoke	EST	2251 FB	P402	3rd Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P405	3rd Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P406	3rd Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P409	3rd Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P412	3rd Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P413	3rd Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P416	3rd "A" Stairwell	Pass
Photoelectric Smoke	EST	2251 FB	P417	3rd "A" Lobby	Pass - Visual
Photoelectric Smoke	EST	2251 FB	P418	3rd "A" Lobby Trashroom	Pass
Photoelectric Smoke	EST	2251 FB	P420	3rd Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P423	3rd Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P426	3rd Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P429	3rd Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P432	3rd Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P435	3rd Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P438	3rd Floor "B" Stairwell	Pass
Photoelectric Smoke	EST	2251 FB	P439	3rd Floor "B" Lobby	Pass - Visual
Photoelectric Smoke	EST	2251 FB	P440	3rd Floor "B" Lobby Trashrom	Pass
Photoelectric Smoke	EST	2251 FB	P441	3rd Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P444	3rd Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P445	3rd Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P448	3rd Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P451	3rd Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P452	3rd Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P455	3rd Floor West Stairwell	Pass
Photoelectric Smoke	EST	2251 FB	P501	4th Floor East Stairwell	Pass
Photoelectric Smoke	EST	2251 FB	P502	4th Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P505	4th Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P506	4th Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P509	4th Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P512	4th Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P513	4th Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P516	4th Floor "A" Stairwell	Pass
Photoelectric Smoke	EST	2251 FB	P517	4th Floor "A" Lobby	Pass - Visual
Photoelectric Smoke	EST	2251 FB	P518	4th Floor "A" Trashroom	Pass
Photoelectric Smoke	EST	2251 FB	P520	4th Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P523	4th Floor Hallway	Pass



FIRE EQUIPMENT INCORPORATED

Photoelectric Smoke	EST	2251 FB	P526	4th Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P529	4th Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P532	4th Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P535	4th Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P538	4th Floor "B" Trashroom	Pass
Photoelectric Smoke	EST	2251 FB	P539	4th Floor "B" Lobby	Pass - Visual
Photoelectric Smoke	EST	2251 FB	P540	4th Floor "B" Stairwell	Pass
Photoelectric Smoke	EST	2251 FB	P541	4th Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P544	4th Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P545	4th Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P548	4th Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P551	4th Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P552	4th Floor Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P555	4th Floor West Stairwell	Pass
Pull Station	Secutron INC	RMS 1T	M401	3rd Floor East Stairwell	Pass
Pull Station	Secutron INC	RMS 1T	M402	3rd Floor "A" Stairwell	Pass
Pull Station	Secutron INC	RMS 1T	M403	3rd Floor "B" Stairwell	Pass
Pull Station	Secutron INC	RMS 1T	M404	3rd Floor West Stairwell	Pass
Pull Station	Secutron INC	RMS 1T	M501	4th Floor East Stairwell	Pass
Pull Station	Secutron INC	RMS 1T	M502	4th Floor "A" Stairwell	Pass
Pull Station	Secutron INC	RMS 1T	M503	4th Floor "B" Stairwell	Pass
Pull Station	Secutron INC	RMS 1T	M504	4th Floor West Stairwell	Pass
Power Supply	Silent Knight	5495		4th Floor "A" Trashroom	Pass
Power Supply	Silent Knight	5495		6th Floor "B" Trashroom	Pass
Power Supply	Silent Knight	5495		2nd Floor "B" Trashroom	Pass
Power Supply	Silent Knight	5495		Ground Fl. by Bldg. panel	Pass
A/V appliance	System Sensor	P2R		3rd Floor Hallways	Pass - Visual
A/V appliance	System Sensor	P2R		4th Floor Hallways	Pass - Visual
Pull Station	Harrington Signal Inc.	Dual Action	125	Pent B Elev Machine RM	Pass
Pull Station	Harrington Signal Inc.	Dual Action	103	Building A Roof Penthouse Elev Lobby	Pass
Pull Station	Harrington Signal Inc.	Dual Action	109	Building A Penthouse Elev Mach RM	Pass
Pull Station	Harrington Signal Inc.	Dual Action	M818	Building B Roof Elev Lobby	Pass
Pull Station	Harrington Signal Inc.	Dual Action	M703	Building B 6th Floor Elev Lobby	Pass
Pull Station	Harrington Signal	Dual Action	M704	Building B 6th Floor	Pass



FIRE EQUIPMENT INCORPORATED

	Inc.			right end pull	
Pull Station	Harrington Signal Inc.	Dual Action	M701	Building A 6th Floor left end pull	Pass
Pull Station	Harrington Signal Inc.	Dual Action	M702	Building A 6th Floor Elev Lobby Pull	Pass
Pull Station	Harrington Signal Inc.	Dual Action	M601	Building A 5th left end pull	Pass
Pull Station	Harrington Signal Inc.	Dual Action	M602	Building A 5th Elev Lobby Pull	Pass
Pull Station	Harrington Signal Inc.	Dual Action	M603	Building B 5th Floor Elev Lobby Pull	Pass
Pull Station	Harrington Signal Inc.	Dual Action	M604	5th Floor Building B right end pull	Pass
Pull Station	Harrington Signal Inc.	Dual Action	M302	2nd Floor Building A Elev Lobby Pull	Pass
Pull Station	Harrington Signal Inc.	Dual Action	M303	2nd Floor Building B Elev Lobby Pull	Pass
Pull Station	Harrington Signal Inc.	Dual Action	M304	2nd Floor Building B Right Exit pull	Pass
Pull Station	Harrington Signal Inc.	Dual Action	M301	2nd Floor Building A Left Exit pull	Pass
Pull Station	Harrington Signal Inc.	Dual Action	M201	1st Floor Building A Left Pull	Pass
Pull Station	Harrington Signal Inc.	Dual Action	M202	1st Floor Building A Elev Lobby Pull	Pass
Pull Station	Harrington Signal Inc.	Dual Action	M203	1st Floor Building B Elev Lobby Pull	Pass
Pull Station	Harrington Signal Inc.	Dual Action	M204	1st Floor Building B Right End	Pass
Pull Station	Harrington Signal Inc.	Dual Action	M102	Garage Lobby Building A front lobby	Pass
Pull Station	Harrington Signal Inc.	Dual Action	M103	Garage Lobby Building A Rear Exit	Pass
Pull Station	Harrington Signal Inc.	Dual Action	M104	Central Garage Area Pulls and Heats	Pass
Pull Station	Harrington Signal Inc.	Dual Action	M108	Garage Lobby Building B rear exit pull	Pass
Pull Station	Harrington Signal Inc.	Dual Action	M109	Garage Lobby Building B front exit pull	Pass
Heat Detector	System Sensor	B501BH	H826	Pent B Mech Rm.	Pass
Heat Detector	System Sensor	B501BH	H814	Pent B Social Room	Pass
Heat Detector	System Sensor	B501BH	H815	Pent B Social Room Men's Bathroom	Pass
Heat Detector	System Sensor	B501BH	H816	Pent B Social Room Women's Bathroom	Pass
Heat Detector	System Sensor	B501BH	H820	Roof B Mech Rm.	Pass
Heat Detector	System Sensor	B501BH	H801	A Roof Mech Rm.	Pass
Heat Detector	System Sensor	5251B	07	A Penthouse Mech Rm.	Pass
Heat Detector	Fenwal	225 deg.	M104 Puls & Heats	Central Garage Area Pulls and Heats	Pass



FIRE EQUIPMENT INCORPORATED

Heat Detector	Fenwal	225 deg.	M110 Puls & Heats	B Garage Area Pulls and Heats	Pass
Heat Detector	System Sensor	B501BH	H115	B Lobby Laundry Rm.	Pass
Heat Detector	Fenwal	225 deg.	M101	A Garage Heats and Pulls	Pass
Heat Detector	System Sensor	B501BH	M106	Ground fl Laundry Rm.	Pass
Photoelectric Smoke	EST	2251 FB	P829	Pent B Social Rm.	Pass
Photoelectric Smoke	EST	2251 FB	P813	Pent B Social Rm.	Pass
Photoelectric Smoke	EST	2251 FB	P817	Roof B Elev. Lobby	Pass - Visual
Photoelectric Smoke	EST	2251 FB	P819	Roof B Stairwell	Pass
Photoelectric Smoke	EST	2251 FB	P823	Pent B Elevator Mach. Rm.	Pass - Visual
Photoelectric Smoke	EST	2251 FB	P825	Pent B Stairwell	Pass
Photoelectric Smoke	EST	2251 FB	P802	A Roof Stairwell	Pass
Photoelectric Smoke	EST	2251 FB	P804	A Penthouse Apt. Lobby	Pass - Visual
Photoelectric Smoke	EST	2251 FB	P808	A Penthouse Stairwell	Pass
Photoelectric Smoke	EST	2251 FB	P810	A Elev. Mach. Rm	Pass - Visual
Photoelectric Smoke	EST	2251 FB	P751	6th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P752	6th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P755	6th Fl. West Stairwell	Pass
Photoelectric Smoke	EST	2251 FB	P748	6th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P756	6th Fl. B Elev. Lobby by Hallway door	Pass
Photoelectric Smoke	EST	2251 FB	P744	6th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P745	6th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P735	6th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P741	6th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P738	6th Fl. B Trash Rm.	Pass
Photoelectric Smoke	EST	2251 FB	P739	6th Fl. B Elev. Lobby	Pass - Visual
Photoelectric Smoke	EST	2251 FB	P740	6th Fl. B Stairwell	Pass
Photoelectric Smoke	EST	2251 FB	P726	6th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P729	6th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P732	6th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P716	6th Fl. A Stairwell	Pass
Photoelectric Smoke	EST	2251 FB	P717	6th Fl. A Elev. Lobby	Pass - Visual
Photoelectric Smoke	EST	2251 FB	P718	6th Fl. A Trash Rm.	Pass
Photoelectric Smoke	EST	2251 FB	P720	6th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P723	6th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P705	6th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P706	6th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P709	6th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P712	6th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P713	6th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P702	6th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P701	6th Fl. East Stairwell	Pass
Photoelectric Smoke	EST	2251 FB	P648	5th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P651	5th Fl. Hallway	Pass



FIRE EQUIPMENT INCORPORATED

Photoelectric Smoke	EST	2251 FB	P652	5th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P655	5th Fl. West Stairwell	Pass
Photoelectric Smoke	EST	2251 FB	P639	5th Fl. B Elev. Lobby	Pass - Visual
Photoelectric Smoke	EST	2251 FB	P640	5th Fl. B Stairwell	Pass
Photoelectric Smoke	EST	2251 FB	P641	5th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P644	5th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P645	5th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P632	5th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P635	5th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P638	5th Fl. B Trash Rm.	Pass
Photoelectric Smoke	EST	2251 FB	P623	5th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P626	5th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P629	5th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P612	5th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P613	5th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P620	5th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P616	5th Fl. A Stairwell	Pass
Photoelectric Smoke	EST	2251 FB	P252	1st Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P617	5th Fl. A Elev. Lobby	Pass - Visual
Photoelectric Smoke	EST	2251 FB	P618	5th Fl. A Trash Rm.	Pass
Photoelectric Smoke	EST	2251 FB	P348	2nd Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P351	2nd Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P605	5th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P606	5th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P609	5th Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P352	2nd Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P355	2nd Fl. West Stairwell	Pass
Photoelectric Smoke	EST	2251 FB	P339	2nd Fl. B Stairwell	Pass
Photoelectric Smoke	EST	2251 FB	P340	2nd Fl. B Elev. Lobby	Pass - Visual
Photoelectric Smoke	EST	2251 FB	P341	2nd Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P344	2nd Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P345	2nd Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P332	2nd Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P335	2nd Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P338	2nd Fl. B Trash Rm.	Pass
Photoelectric Smoke	EST	2251 FB	P329	2nd Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P323	2nd Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P326	2nd Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P312	2nd Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P313	2nd Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P320	2nd Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P316	2nd Fl. A Stairwell	Pass
Photoelectric Smoke	EST	2251 FB	P317	2nd Fl. A Elev. Lobby	Pass - Visual
Photoelectric Smoke	EST	2251 FB	P318	2nd Fl. A Trash Rm.	Pass
Photoelectric Smoke	EST	2251 FB	P305	2nd Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P306	2nd Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P309	2nd Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P302	2nd Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P301	2nd Fl. East	Pass



FIRE EQUIPMENT INCORPORATED

Photoelectric Smoke	EST	2251 FB	P255	Stairwell 1st Fl. West Stairwell	Pass
Photoelectric Smoke	EST	2251 FB	P245	1st Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P248	1st Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P251	1st Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P241	1st Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P244	1st Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P238	1st Fl. B Stairwell	Pass
Photoelectric Smoke	EST	2251 FB	P239	1st Fl. B Elev. Lobby	Pass
Photoelectric Smoke	EST	2251 FB	P240	1st Fl. B Trash Rm.	Pass
Photoelectric Smoke	EST	2251 FB	P229	1st Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P232	1st Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P235	1st Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P220	1st Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P223	1st Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P226	1st Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P218	1st Fl. A Trash Rm.	Pass
Photoelectric Smoke	EST	2251 FB	P209	1st Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P212	1st Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P213	1st Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P216	1st Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P217	1st Fl. A Elev. Lobby	Pass
Photoelectric Smoke	EST	2251 FB	P201	1st Fl. East Stairwell	Pass
Photoelectric Smoke	EST	2251 FB	P202	1st Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P205	1st Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P206	1st Fl. Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P112	Garage Lobby B Stairwell	Pass
Photoelectric Smoke	EST	2251 FB	P113	B Elev. Lobby	Pass
Photoelectric Smoke	EST	2251 FB	P114	B Front Lobby	Pass
Photoelectric Smoke	EST	2251 FB	P116	B Game Room Hallway	Pass
Photoelectric Smoke	EST	2251 FB	P117	B Game Room	Pass
Photoelectric Smoke	EST	2251 FB	P118	Ground Fl. West Stairwell	Pass
Photoelectric Smoke	EST	2251 FB	P104	Ground fl Manager's Office	Pass
Photoelectric Smoke	EST	2251 FB	P105	Ground Fl. outside of A Laundry Rm.	Pass
Photoelectric Smoke	EST	2251 FB	P107	Ground Fl. A Stairwell	Pass
Photoelectric Smoke	EST	2251 FB	P108	Ground Fl. A Compactor Rm.	Pass
Photoelectric Smoke	EST	2251 FB	P109	Ground Fl. A Elev. Lobby	Pass
Photoelectric Smoke	EST	2251 FB	P110	Ground Fl. A Front Lobby	Pass
Photoelectric Smoke	EST	2251 FB	P111	Ground Fl. B Compactor Rm.	Pass
Photoelectric Smoke	EST	2251 FB	P103	Ground fl Fitness Rm.	Pass
Photoelectric Smoke	EST	2251 FB	P102	Ground Fl. Hallway by office	Pass



FIRE EQUIPMENT INCORPORATED

Photoelectric Smoke	EST	2251 FB	P101	Ground Fl. East Stairwell	Pass
Heat Detector	System Sensor	B501BH	H203	Apt. 101	Pass
Heat Detector	System Sensor	B501BH	H204	Apt. 102	Pass
Heat Detector	System Sensor	B501BH	H207	Apt. 103	Pass
Heat Detector	System Sensor	B501BH	H208	Apt. 104	Pass
Heat Detector	System Sensor	B501BH	H210	Apt. 105	Pass
Heat Detector	System Sensor	B501BH	H211	Apt. 106	Pass
Heat Detector	System Sensor	B501BH	H214	Apt. 107	Pass
Heat Detector	System Sensor	B501BH	H215	Apt. 108	Pass
Heat Detector	System Sensor	B501BH	H221	Apt. 109	Pass
Heat Detector	System Sensor	B501BH	H222	Apt. 110	Pass
Heat Detector	System Sensor	B501BH	H224	Apt. 111	Pass
Heat Detector	System Sensor	B501BH	H225	Apt. 112	Pass
Heat Detector	System Sensor	B501BH	H227	Apt. 113	Pass
Heat Detector	System Sensor	B501BH	H228	Apt. 114	Pass
Heat Detector	System Sensor	B501BH	H230	Apt. 115	Pass
Heat Detector	System Sensor	B501BH	H231	Apt. 116	Pass
Heat Detector	System Sensor	B501BH	H234	Apt. 117	Pass
Heat Detector	System Sensor	B501BH	H237	Apt. 118	Pass
Heat Detector	System Sensor	B501BH	H236	Apt. 119	Pass
Heat Detector	System Sensor	B501BH	H233	Apt. 120	Pass
Heat Detector	System Sensor	B501BH	H242	Apt. 121	Pass
Heat Detector	System Sensor	B501BH	H243	Apt. 122	Pass
Heat Detector	System Sensor	B501BH	H246	Apt. 123	Pass
Heat Detector	System Sensor	B501BH	H247	Apt. 124	Pass
Heat Detector	System Sensor	B501BH	H249	Apt. 125	Pass
Heat Detector	System Sensor	B501BH	H250	Apt. 126	Pass
Heat Detector	System Sensor	B501BH	H253	Apt. 127	Pass
Heat Detector	System Sensor	B501BH	H254	Apt. 128	Pass
Heat Detector	System Sensor	B501BH	H303	Apt. 201	Pass
Heat Detector	System Sensor	B501BH	H304	Apt. 202	Pass
Heat Detector	System Sensor	B501BH	H307	Apt. 203	Pass
Heat Detector	System Sensor	B501BH	H308	Apt. 204	Pass
Heat Detector	System Sensor	B501BH	H310	Apt. 205	Pass
Heat Detector	System Sensor	B501BH	H311	Apt. 206	Pass
Heat Detector	System Sensor	B501BH	H314	Apt. 207	Pass
Heat Detector	System Sensor	B501BH	H315	Apt. 208	Pass
Heat Detector	System Sensor	B501BH	H321	Apt. 209	Pass
Heat Detector	System Sensor	B501BH	H322	Apt. 210	Pass
Heat Detector	System Sensor	B501BH	H324	Apt. 211	Pass
Heat Detector	System Sensor	B501BH	H325	Apt. 212	Pass
Heat Detector	System Sensor	B501BH	H327	Apt. 213	Pass
Heat Detector	System Sensor	B501BH	H328	Apt. 214	Pass
Heat Detector	System Sensor	B501BH	H330	Apt. 215	Pass
Heat Detector	System Sensor	B501BH	H331	Apt. 216	Pass
Heat Detector	System Sensor	B501BH	H333	Apt. 217	Pass
Heat Detector	System Sensor	B501BH	H334	Apt. 218	Pass
Heat Detector	System Sensor	B501BH	H336	Apt. 219	Pass
Heat Detector	System Sensor	B501BH	H337	Apt. 220	Pass
Heat Detector	System Sensor	B501BH	H342	Apt. 221	Pass
Heat Detector	System Sensor	B501BH	H343	Apt. 222	Pass
Heat Detector	System Sensor	B501BH	H346	Apt. 223	Pass
Heat Detector	System Sensor	B501BH	H347	Apt. 224	Pass
Heat Detector	System Sensor	B501BH	H349	Apt. 225	Pass



FIRE EQUIPMENT INCORPORATED

Heat Detector	System Sensor	B501BH	H350	Apt. 226	Pass
Heat Detector	System Sensor	B501BH	H353	Apt. 227	Pass
Heat Detector	System Sensor	B501BH	H354	Apt. 228	Pass
Heat Detector	System Sensor	B501BH	H603	Apt. 501	Pass
Heat Detector	System Sensor	B501BH	H604	Apt. 502	Pass
Heat Detector	System Sensor	B501BH	H607	Apt. 503	Pass
Heat Detector	System Sensor	B501BH	H608	Apt. 504	Pass
Heat Detector	System Sensor	B501BH	H610	Apt. 505	Pass
Heat Detector	System Sensor	B501BH	H611	Apt. 506	Pass
Heat Detector	System Sensor	B501BH	H614	Apt. 507	Pass
Heat Detector	System Sensor	B501BH	H615	Apt. 508	Pass
Heat Detector	System Sensor	B501BH	H621	Apt. 509	Pass
Heat Detector	System Sensor	B501BH	H622	Apt. 510	Pass
Heat Detector	System Sensor	B501BH	H625	Apt. 512	Pass
Heat Detector	System Sensor	B501BH	H627	Apt. 513	Pass
Heat Detector	System Sensor	B501BH	H628	Apt. 514	Pass
Heat Detector	System Sensor	B501BH	H630	Apt. 515	Pass
Heat Detector	System Sensor	B501BH	H631	Apt. 516	Pass
Heat Detector	System Sensor	B501BH	H633	Apt. 517	Pass
Heat Detector	System Sensor	B501BH	H636	Apt. 519	Pass
Heat Detector	System Sensor	B501BH	H637	Apt. 520	Pass
Heat Detector	System Sensor	B501BH	H642	Apt. 521	Pass
Heat Detector	System Sensor	B501BH	H643	Apt. 522	Pass
Heat Detector	System Sensor	B501BH	H646	Apt. 523	Pass
Heat Detector	System Sensor	B501BH	H647	Apt. 524	Pass
Heat Detector	System Sensor	B501BH	H649	Apt. 525	Pass
Heat Detector	System Sensor	B501BH	H650	Apt. 526	Pass
Heat Detector	System Sensor	B501BH	H653	Apt. 527	Pass
Heat Detector	System Sensor	B501BH	H654	Apt. 528	Pass
Heat Detector	System Sensor	B501BH	H703	Apt. 601	Pass
Heat Detector	System Sensor	B501BH	H704	Apt. 602	Pass
Heat Detector	System Sensor	B501BH	H707	Apt. 603	Pass
Heat Detector	System Sensor	B501BH	H708	Apt. 604	Pass
Heat Detector	System Sensor	B501BH	H710	Apt. 605	Pass
Heat Detector	System Sensor	B501BH	H711	Apt. 606	Pass
Heat Detector	System Sensor	B501BH	H714	Apt. 607	Pass
Heat Detector	System Sensor	B501BH	H715	Apt. 608	Pass
Heat Detector	System Sensor	B501BH	H721	Apt. 609	Pass
Heat Detector	System Sensor	B501BH	H722	Apt. 610	Pass
Heat Detector	System Sensor	B501BH	H724	Apt. 611	Pass
Heat Detector	System Sensor	B501BH	H725	Apt. 612	Pass
Heat Detector	System Sensor	B501BH	H727	Apt. 613	Pass
Heat Detector	System Sensor	B501BH	H728	Apt. 614	Pass
Heat Detector	System Sensor	B501BH	H730	Apt. 615	Pass
Heat Detector	System Sensor	B501BH	H731	Apt. 616	Pass
Heat Detector	System Sensor	B501BH	H733	Apt. 617	Pass
Heat Detector	System Sensor	B501BH	H734	Apt. 618	Pass
Heat Detector	System Sensor	B501BH	H736	Apt. 619	Pass
Heat Detector	System Sensor	B501BH	H737	Apt. 620	Pass
Heat Detector	System Sensor	B501BH	H742	Apt. 621	Pass
Heat Detector	System Sensor	B501BH	H743	Apt. 622	Pass
Heat Detector	System Sensor	B501BH	H746	Apt. 623	Pass
Heat Detector	System Sensor	B501BH	H747	Apt. 624	Pass
Heat Detector	System Sensor	B501BH	H749	Apt. 625	Pass
Heat Detector	System Sensor	B501BH	H750	Apt. 626	Pass



FIRE EQUIPMENT INCORPORATED

Heat Detector	System Sensor	B501BH	H753	Apt. 627	Pass
Heat Detector	System Sensor	B501BH	H754	Apt. 628	Pass
A/V appliance	System Sensor	P2R		Ground floor	Pass
A/V appliance	System Sensor	P2R		1st floor	Pass - Visual
A/V appliance	System Sensor	P2R		2nd floor	Pass - Visual
A/V appliance	System Sensor	P2R		5th floor	Pass - Visual
A/V appliance	System Sensor	P2R		6th floor	Pass - Visual